



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	SIEX-NC 1230 360 & 610 psi (25 & 42 bar) Engineered Fire Suppression Systems
Flow Calculation Software:	FK-5-1-12 Calculation program Version 7.4
Design Manual:	System Design Manual, UF-MD-NC, 07-05-2018
Components Manual:	System Components Manual, UF-MC-NC, 07-05-2018
Installation Manual:	Installation Manual, UF-MI-NC, 01-01-2017
Maintenance Manual:	Maintenance Manual, UF-MC-NC, 11-01-2018

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Siex 2001, S.L.
Polígono Industrial Villalonquéjar
C/ Merindad de Montija Nº 6
09001 Burgos
Spain

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):


<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i>	
5600	April 2013

FM Approvals Listing Class: 5612

Original Approval Project Identification: 3062401
Subsequent Revisions: N/A

Approval Granted: 22 May 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com


James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

22 May 2018

Date



Member of the FM Global Group



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment:

System Designation:	SIEX-NC 1230 S-FLOW 465, 490, 725 & 800 psi (32, 34, 50 & 55 bar) Engineered Fire Suppression Systems
Flow Calculation Software:	FK-5-1-12 Calculation program Version 7.4
Design Manual:	System Design Manual, UF-MD-NC, 07-05-2018
Components Manual:	System Components Manual, UF-MC-NC, 07-05-2018
Installation Manual:	Installation Manual, UF-MI-NC, 01-01-2017
Maintenance Manual:	Maintenance Manual, UF-MC-NC, 11-01-2018

Approval Guide Listing Category: Fixed Extinguishing Systems, Clean Agent Fire Extinguishing Systems

Siex 2001, S.L.
Polígono Industrial Villalonquéjar
C/ Merindad de Montija Nº 6
09001 Burgos
Spain

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standard(s):


<i>Approval Standards</i>	<i>Date</i>
<i>Class Number</i> 5600	April 2013

FM Approvals Listing Class: 5612

Original Approval Project Identification: 3062401
Subsequent Revisions: N/A

Approval Granted: 22 May 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com


James E. Marquedant
Manager - Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

22 May 2018

Date



Member of the FM Global Group