

---

**Requested by** RG Systems  
Industrial Area Villalonquéjar Number 6  
Merindad de Montija Street, Burgos, SPAIN

**Order** 1 June 2009 / José Ignacio Melgosa (VTT-V-37976-09)

**Handled by** VTT Technical Research Centre of Finland  
P.O.Box 1000, FI-02044 VTT, Finland  
Contact person: Peter Grönberg

---

**Task** Preliminary evaluation of the extinguishing effectiveness of the RG Systems fire protection system for local applications in machinery spaces according to IMO MSC/Circ.913

**Date of test** 19 - 24 October, 2007.

**The product tested** RG Systems water mist fire protection system, RG Systems EMM-523856A nozzles.


**Test method** IMO MSC/Circ.913 Guidelines for the approval of fixed water-based local application fire-fighting systems for use in category A machinery spaces with deviations listed in Chapter 4 of this test report.


**Test site** VTT large fire test hall.

**Summary** This report describes six preliminary fire extinguishing tests that were conducted applying the test procedures of the IMO MSC/Circ.913 on the guidelines for approval of fixed water-based local application fire-fighting systems. The tested nozzle type was RG Systems EMM-523856A. The tests do not represent a full test series and can therefore not be held as official tests.

The nozzle EMM-523856A was tested for protection of 6 MW test spray fires between 1.5 m and 2 m from the nozzle grid, with 4 m nozzle spacing and a minimum pressure of 100 bar at the nozzles.

Espoo, 3 July 2009

  
Kimmo Kaukanen  
Team Leader

  
Peter Grönberg  
Research Scientist

**Distribution** Client Original  
VTT/Archives Original